

Lab Safety Officer Weekly Checklist

Date _____ LSO _____ Location _____

Faculty Group _____

Initial

First Aid and Spill kits are stocked and accessible

Appropriate Personal Protective Equipment is available for lab personnel

All vials/glassware/bottles containing chemicals and waste are clearly labeled and stored properly

All flammable chemicals are stored properly and no chemicals are stored on the floor

Sharps are in appropriate Containers

Hood sashes are closed and lab entrance doors are closed

Nothing flammable near heating/cooling vents

All exists and pathways are unobstructed

No items within 18 inches of ceiling

Eyewash stations have been flushed and tagged

Faculty Signature _____